



NEMA 4 PAD CONNECTOR




1-3/4 INCH STUD

DETAIL A
COPPER PAD CONNECTOR
FOR STUD TERMINAL



DETAIL B
NEUTRAL BUSHING 1N

DETAIL 1: Primary side neutral point 1N connection detail.




CONDUIT FIXING DETAIL


DETAIL 2: Conduit fixing to transformer yard fire Wall.

NOTES:

- 1.- Use the same type of support for the installation of the vertical conduit.




GROUNDING PLATE DETAIL



GROUNDING PLATE GENERAL ARRANGEMENT

DETAIL 3: Grounding plate connection.



300 mm² GREEN-YELLOW
GROUNDING CABLE
TO BUSHING 1N

2 INCH
HDG STEEL CONDUIT

GROUNDING BUSHING

2 INCH
HDG STEEL CONDUIT

300 mm² GREEN-YELLOW
GROUNDING CABLE
TO BUSHING 1N

CONDUIT SUPPORT
SEE DETAIL 2



DETAIL 4: Conduit laying.